

Skolsal (60m²)

| Armatur | Best. nummer | Bestyckning | Antal | Mont. h (m ö.g) |
|-------------------------|--------------------------|-------------|-------|------------------|
| Fovea system 0/100 asym | Se produktpärm/prislista | 1x80W | 6 | 2.20 |
| Fovea II 50/50 | Se produktpärm/prislista | 1x49W | 3 | 2.20 |

| Medelbelysning: | Maxluminans i tak : | Systemeffekt : | Rumsmått (LxBxH) | Beräkn. indrag |
|-----------------|-----------------------|-----------------------|------------------|----------------|
| 507 lux | 740 cd/m ² | 11.2 W/m ² | 7 x 8.6 x 2.7 m | 0.5 m |

